




TH1-1063751/2025

തീയതി 21.05.2025

SANITATION CERTIFICATE

AS Per the Inspection report of the Health Inspector of this institution dated:05/03/2025 I here by certified that the sanitation condition of **CHINMAYA VIDYALAYA, THAZHATHANGADY, KOTTAYAM** is satisfactory to the health and hygienic point of view by maintaining the required standards at the time of inspection.

This certificate is issued only to be produced before the Kerala Government Education Department and Central Board of Secondary Education.


Health Supervisor
Kottayam Municipality

TO,
The Chinmaya Vidyalaya
Thazhathangady
Kottayam

A.J.L.G
CLEAN CITY MANAGER
(CORPORATION / MUNICIPALITY)
PE- G 35901
PUBLIC HEALTH AND ENVIRONMENT
MANAGEMENT WING
LOCAL SELF GOVT DEPARTMENT
GOVT. OF KERALA





Estd 1999

INTEGRATED ENVIRONMENTAL SOLUTIONS

Approved Laboratory By Kerala State Pollution Control Board
ENGINEERS & CONSULTANTS, CHEMISTS

Grace Building, Vadakenada, Thirunakkara, Kottayam-1

Ph: 0481-2302216, Mob: 9947248916, 9447659216

www.integratedenvironmentalsolutions.in, Email: ieslabkerala@gmail.com



M/s.Chinmaya Vidhyalaya
Thazhathangadi P.O
Kottayam

WATER TEST REPORT

Report Number : IES/W/RT/202501383/25

Report date : 26.11.2025

Sample mark : Water Sample collected By party

Page : 1 of 1

Sample descript : Well Water

Received on : 22.11.2025

Sl.NO.	PARAMETERS	RESULTS	Requirement (acceptable limit) as per IS 10500,R2012 2 nd Rev.
1	pH	6.5	6.5 -8.5
2	Colour Hazen unit	ND	5
3	Odour	Agreable	Agreable
4	Turbidity (NTU)	ND	1.0
5	Total Dissolved Solids, (mg/L)	20.0	500
6	Total Alkalinity as CaCO ₃ (mg/L)	8.0	200
7	Chlorides as Cl- (mg/L)	8.0	250
8	Total Hardness as CaCO ₃ (mg/L)	8.0	200
9	Calcium as Ca (mg/L)	1.60	75
10	Magnesium as Mg (mg/L)	0.97	30
11	Residual Chlorine (mg/L)	ND	0.2
12	Ammoniacal Nitrogen (mg/L)	ND	0.5
13	Sulphates as SO ₄ ²⁻ (mg/L)	ND	200
14	Total Iron as Fe (mg/L)	ND	1.0
15	Nitrite as NO ₂ ⁻ (mg/L)	ND	Absent
16	Nitrates as NO ₃ ⁻ (mg/L)	ND	45
17	Total Coliforms /100ml	Nil	Absent
18	Fecal Coli forms /100ml	Nil	Absent

Note - ND -- Not detected



Authorised signatory
SCIENTIST
INTEGRATED ENVIRONMENTAL SOLUTIONS
APPROVED BY KERALA STATE P C B
KOTTAYAM

Remarks: Satisfactory Result

Terms and condition:

- Test results shown in this test report related only to the items tested
- The test report shall not to be reproduced any where in full and in same format without the approval of the laboratory
- The test items will not be retained for more than 15 days from the date of issue of test report in the case of perishable items and 3 months in the case of metal samples unless otherwise agreed with the customer on as required by the applicable regulation (exceptional for microbiology and waste water)



Our Services:

- Water Testing • Effluent Water Analysis • Air & Stack Emission Monitoring • Sound Level Test etc.